

The following items have changed in 22.4 based on the feedback post publication.

Only the redlines identified in this draft are open for comment. Comments on sections outside the scope of this ballot may be deferred until the next edition/addendum of the standard. Please coordinate your comments with your company's voting member. The system also permits non-voting members and guests to submit comments by entering the ballot ID on the login page and their contact information.

The following changes were made to the document and open for comment:

1. Equation 1 got screwed up in the formatting somehow. The correct equation has replaced it.
2. Equation B.4 was mislabeled, and the label was fixed.
3. Equation 5 had an extra zero. The zero was removed.
4. Equation 4 was missing absolute value brackets.
5. Figure 3 was not calculated correctly due to the Equation 4 error.
6. Figures 4 and 5 needed to be updated to reflect the change from Figure 3.
7. Equation B.1.3 was missing absolute value brackets and was incorrectly labeled B.2.
8. Figures B.1 through B.6 require updating as they had incorrect values.

Manual of Petroleum Measurement Standards, Chapter 22.4

Testing Protocol for Pressure, Differential Pressure, and Temperature Measuring Devices

FIRST EDITION, JULY 2018

ADDENDUM 1, XXXXX, 2021



AMERICAN PETROLEUM INSTITUTE

Table 2—Minimum Required Test Points

Test Points (% of Maximum Test Value)
0% – 2% – 4% – 6% – 8% – 10% – 20% – 40% – 60% – 80% – 100%

4.1.1.1 API 22.4 Baseline Accuracy Calculation

API 22.4 Baseline Accuracy shall be calculated for each required test point in Table 2 as root mean square of linearity and the maximum repeatability and hysteresis values:

$$\text{API 22.4 Baseline Accuracy} = \sqrt{(\text{Linearity})^2 + (\max(\text{Repeatability}))^2 + (\max(\text{Hysteresis}))^2}$$

$$\text{2.4 Baseline Accuracy} = \sqrt{(\text{Linearity})^2 + (\max(\text{Repeatability}))^2 + (\max(\text{Hysteresis}))^2 + \bar{y}^2 + (\text{Reference Accuracy})^2} \quad (1)$$

(See Annex B.1 for an example of linearity, hysteresis, repeatability, and API 22.4 Baseline Accuracy calculations.)

4.1.1.2 Linearity Calculation

Linearity shall be calculated for each test point in Table 2 as the average of all test upscale and downscale values:

(See Annex B.1.1 for an example of linearity calculations.)

$$\text{Linearity} = \Sigma \frac{DUT - Ref}{\text{Number of Test Points}} \quad (2)$$

4.1.1.3 Repeatability Calculation

Repeatability shall be calculated for each test point in Table 2 as the maximum minus the minimum of all repeat test upscale and downscale values:

$$\text{Repeatability} = \left(\max([DUT - Ref]_{\text{downscale or upscale}} - [DUT - Ref]_{\text{upscale or downscale}}) \right) / 2 \quad (3)$$

Due to the limited number of test points, the transmitter repeatability error shall be reported as the maximum of these calculated values. (See Annex B.1.2 for an example of repeatability calculations.)

4.1.1.4 Hysteresis Calculation

Hysteresis shall be calculated for each test point in Table 2 as the maximum downscale minus upscale value of each repeat test:

$$\text{Hysteresis} = \max(|[DUT - Ref]_{\text{downscale}} - [DUT - Ref]_{\text{upscale}}|)_{\text{each repeat test}}$$

$$\text{Hysteresis} = \max([DUT - Ref]_{\text{downscale}} - [DUT - Ref]_{\text{upscale}})_{\text{each repeat test}} \quad (4)$$

Due to the limited number of test points the transmitter hysteresis shall be reported as the maximum of these calculated values. (See Annex B.1.3 for an example of hysteresis calculations.)

4.12 Temperature Transmitter Testing

Performance of the temperature measurement in an Electronic Flow Measurement (EFM) system is dependent on

RTD sensors are manufactured to specific tolerances based on their performance classification. For example, Class A and Class B RTDs have the following manufacturing tolerance:

where

$|T_{oc}|$ is the absolute value of temperature $|T_{oc}|$ in °F;

T_{θ_n} is the maximum temperature error at temperature T_{θ_n} .

NOTE 2 To minimize the impact of sensor uncertainty, the sensor can be characterized and the characterized sensor used during calibration of the EFM/transmitter electronics.

The electronics shall be allowed to stabilize at the ambient temperature prescribed for each test at a minimum of one hour prior to commencing. The RTD/Sensor temperature shall be calculated from the reference standard temperature if a characterized sensor is used. The temperature difference shall be calculated from the RTD/Sensor temperature, if available.

1. Baseline Test—Electronics Ambient Temperature Approximately 70 °F/21 °C

1. Baseline Test—Electronics Ambient Temperature Approximately 70 °F/21 °C						
Test Temperature	Temperature of Reference Standard	RTD/Sensor Characterized Temperature (If Available)	EFM/ Transmitter Reading	Temperature Difference	Class A Spec	Class B Spec
	°F/°C	°F/°C	°F/°C	°F/°C	°F/°C	°F/°C
0 °F/−18 °C						
32 °F/0 °C						
68 °F/20 °C						
104 °F/40 °C						
140 °F/60 °C						
2. Hot Test—Electronics Ambient Temperature Approximately 140 °F/60 °C						

Test Temperature	Temperature of Reference Standard	RTD/Sensor Characterized Temperature (If Available)	EFM/ Transmitter Reading	Temperature Difference	Class A Spec	Class B Spec
	°F/°C	°F/°C	°F/°C	°F/°C	°F/°C	°F/°C
32 °F/0 °C						
68 °F/20 °C						
104 °F/40 °C						
3. Cold Test—Electronics Ambient Temperature Approximately 40 °F/40 °C						
Test Temperature	Temperature of Reference Standard	RTD/Sensor Characterized Temperature (If Available)	EFM/ Transmitter Reading	Temperature Difference	Class A Spec	Class B Spec

Repeatability/Hysteresis Calculation				
Test Point	Repeatability		Test Point	Hysteresis
	Upscale	Downscale		
0%		0.0235		
2%	0.0224	0.0282	2%	0.0582
4%	0.0202	0.0205	4%	0.0427
6%	0.0255	0.0040	6%	0.0657
8%	0.0132	0.0106	8%	0.0264
10%	0.0113	0.0143	10%	0.0460
20%	0.0192	0.0263	20%	0.0466
40%	0.0308	0.0080	40%	0.0321
60%	0.0264	0.0138	60%	0.0597
80%	0.0161	0.0175	80%	0.0510
100%	0.0283			

Repeatability/Hysteresis Calculation				
Test Point			Test Point	Hysteresis
	Upscale	Downscale		
0%		0.0235		
2%	0.0224	0.0282	2%	0.0430
4%	0.0202	0.0205	4%	0.0427
6%	0.0255	0.0040	6%	-0.0127
8%	0.0132	0.0106	8%	0.0264
10%	0.0113	0.0143	10%	0.0053
20%	0.0192	0.0263	20%	0.0466
40%	0.0308	0.0080	40%	0.0321
60%	0.0264	0.0138	60%	0.0207
80%	0.0161	0.0175	80%	0.0510
100%	0.0283			

Figure 3—Section 6.4.1, API 22.4 Baseline Accuracy—Repeatability/Hysteresis Calculations

Summary Calculations														
Test Point	Linearity				Repeatability			Hysteresis			API 22.4 Baseline Accuracy			Ref. Std.
Ref. Value	UOM	% MVT	% Reading	UOM	% MVT	% Reading	UOM	% MVT	% Reading	UOM	% MVT	% Reading	% Reading	
0%	0.0	0.0040	0.004%		0.0308	0.031%					+/- 0.0311	+/- 0.031%		See Note
2%	2.0	-0.0014	-0.001%	-0.072%	0.0308	0.031%	1.542%	0.0582	0.058%	2.910%	+/- 0.0659	+/- 0.066%	+/- 3.294%	+/- 0.025%
4%	4.0	0.0015	0.002%	0.038%	0.0308	0.031%	0.771%	0.0427	0.043%	1.068%	+/- 0.0527	+/- 0.053%	+/- 1.318%	+/- 0.025%
6%	6.0	-0.0056	-0.006%	-0.094%	0.0308	0.031%	0.514%	0.0657	0.066%	1.095%	+/- 0.0728	+/- 0.073%	+/- 1.213%	+/- 0.025%
8%	8.0	-0.0107	-0.011%	-0.134%	0.0308	0.031%	0.386%	0.0264	0.026%	0.330%	+/- 0.0420	+/- 0.042%	+/- 0.525%	+/- 0.025%
10%	10.0	-0.0070	-0.007%	-0.070%	0.0308	0.031%	0.308%	0.0460	0.046%	0.460%	+/- 0.0558	+/- 0.056%	+/- 0.558%	+/- 0.025%
20%	20.0	-0.0127	-0.013%	-0.063%	0.0308	0.031%	0.154%	0.0466	0.047%	0.233%	+/- 0.0573	+/- 0.057%	+/- 0.287%	+/- 0.025%
40%	40.0	0.0027	0.003%	0.007%	0.0308	0.031%	0.077%	0.0321	0.032%	0.080%	+/- 0.0446	+/- 0.045%	+/- 0.112%	+/- 0.025%
60%	60.0	-0.0050	-0.005%	-0.008%	0.0308	0.031%	0.051%	0.0597	0.060%	0.099%	+/- 0.0674	+/- 0.067%	+/- 0.112%	+/- 0.025%
80%	80.0	-0.0074	-0.007%	-0.009%	0.0308	0.031%	0.039%	0.0510	0.051%	0.064%	+/- 0.0601	+/- 0.060%	+/- 0.075%	+/- 0.025%
100%	100.0	0.0053	0.005%	0.005%	0.0308	0.031%	0.031%				+/- 0.0313	+/- 0.031%	+/- 0.031%	+/- 0.025%


NOTE Reference Standard Accuracy at zero points only apply to devices where the zero is determined by using a

reference standard.

Summary Calculations															
Test Point	Linearity			Repeatability			Hysteresis			API22.4 Baseline Accuracy			Ref. Std.		
Ref. Value	UOM	% MVT	% Reading	UOM	% MVT	% Reading	UOM	% MVT	% Reading	UOM	% MVT	% Reading	% Reading		
0%	0.0	0.0040	0.004%	0.0235	0.024%					+/-	0.0238	+/-	0.024%	See Note	
2%	2.0	-0.0014	-0.001%	-0.072%	0.0282	0.028%	1.408%	0.0430	0.043%	2.150%	+/-	0.0514	+/-	0.051%	+/- 0.025%
4%	4.0	0.0015	0.002%	0.038%	0.0205	0.021%	0.513%	0.0427	0.043%	1.068%	+/-	0.0474	+/-	0.047%	+/- 0.025%
6%	6.0	-0.0056	-0.006%	-0.094%	0.0255	0.025%	0.425%	-0.0127	-0.013%	-0.212%	+/-	0.0290	+/-	0.029%	+/- 0.025%
8%	8.0	-0.0107	-0.011%	-0.134%	0.0132	0.013%	0.164%	0.0264	0.026%	0.330%	+/-	0.0314	+/-	0.031%	+/- 0.025%
10%	10.0	-0.0070	-0.007%	-0.070%	0.0143	0.014%	0.143%	0.0053	0.005%	0.053%	+/-	0.0168	+/-	0.017%	+/- 0.025%
20%	20.0	-0.0127	-0.013%	-0.063%	0.0263	0.026%	0.132%	0.0466	0.047%	0.233%	+/-	0.0550	+/-	0.055%	+/- 0.025%
40%	40.0	0.0027	0.003%	0.007%	0.0308	0.031%	0.077%	0.0321	0.032%	0.080%	+/-	0.0446	+/-	0.045%	+/- 0.025%
60%	60.0	-0.0050	-0.005%	-0.008%	0.0264	0.026%	0.044%	0.0207	0.021%	0.034%	+/-	0.0339	+/-	0.034%	+/- 0.025%
80%	80.0	-0.0074	-0.007%	-0.009%	0.0175	0.017%	0.022%	0.0510	0.051%	0.064%	+/-	0.0544	+/-	0.054%	+/- 0.025%
100%	100.0	0.0053	0.005%	0.005%	0.0283	0.028%	0.028%				+/-	0.0288	+/-	0.029%	+/- 0.025%

NOTE Reference Standard Accuracy at zero points only apply to devices where the zero is determined by using a reference standard.

Figure 4—Section 6.4.1, API 22.4 Baseline Accuracy—Summary Calculations






Figure 5—Section 6.4.1, API 22.4 Baseline Accuracy—Test Results

Annex B (normative)

Linearity, Hysteresis, Repeatability, API 22.4 Baseline Accuracy and Calculations

B.1 Example Calculations

Figure B.1 shows an example report of the API 22.4 Baseline Accuracy test results including the calculated test error and the reference standard percentage of reading accuracy at each test point. Examples of the calculation of linearity, hysteresis, repeatability, and API 22.4 Baseline Accuracy are provided.

Test Cycle	1			2			3			Ref. Std.
Test Point	Ref. Value	DUT Value	Difference	Ref. Value	DUT Value	Difference	Ref. Value	DUT Value	Difference	% Reading
1 0%	-0.0010	-0.0200	-0.0190	-0.0023	0.0033	0.0057	0.0013	0.0300	0.0287	
2 2%	1.9980	1.9800	-0.0180	1.9977	2.0133	0.0157	2.0033	2.0100	0.0067	+/- 0.025%
3 4%	3.9977	3.9700	-0.0277	4.0000	4.0233	0.0233	4.0013	4.0033	0.0020	+/- 0.025%
4 6%	5.9967	6.0200	0.0233	5.9987	6.0100	0.0113	5.9967	6.0100	0.0133	+/- 0.025%
5 8%	7.9993	7.9667	-0.0327	7.9973	7.9667	-0.0307	7.9977	8.0067	0.0090	+/- 0.025%
6 10%	9.9967	10.0200	0.0233	10.0007	10.0133	0.0127	9.9990	10.0100	0.0110	+/- 0.025%
7 20%	20.0023	19.9667	-0.0357	20.0027	20.0300	0.0273	20.0010	19.9800	-0.0210	+/- 0.025%
8 40%	40.0013	39.9733	-0.0280	40.0010	39.9900	-0.0110	40.0020	39.9767	-0.0253	+/- 0.025%
9 60%	59.9970	60.0333	0.0363	60.0023	60.0167	0.0143	59.9990	60.0300	0.0310	+/- 0.025%
10 80%	79.9980	80.0067	0.0087	79.9967	80.0100	0.0133	79.9983	79.9967	-0.0017	+/- 0.025%
11 100%	100.0007	100.0100	0.0093	99.9997	99.9733	-0.0263	100.0013	100.0267	0.0253	+/- 0.025%
12 80%	80.0010	80.0133	0.0123	80.0033	79.9667	-0.0367	79.9973	79.9967	-0.0007	+/- 0.025%
13 60%	60.0007	59.9667	-0.0340	59.9970	59.9800	-0.0170	59.9973	60.0167	0.0193	+/- 0.025%
14 40%	39.9990	39.9700	-0.0290	40.0027	40.0033	0.0007	39.9997	39.9900	-0.0097	+/- 0.025%
15 20%	20.0000	20.0067	0.0067	20.0003	20.0133	0.0130	19.9980	19.9700	-0.0280	+/- 0.025%
16 10%	9.9997	10.0000	0.0003	10.0020	10.0200	0.0180	10.0033	9.9933	-0.0100	+/- 0.025%
17 8%	8.0023	7.9900	-0.0123	8.0017	7.9767	-0.0250	8.0020	8.0100	0.0080	+/- 0.025%
18 6%	5.9997	6.0033	0.0037	5.9993	6.0000	0.0007	6.0007	5.9933	-0.0073	+/- 0.025%
19 4%	3.9997	3.9667	-0.0330	3.9980	4.0167	0.0187	4.0007	3.9900	-0.0107	+/- 0.025%
20 2%	2.0007	1.9700	-0.0307	2.0027	2.0267	0.0240	1.9973	1.9700	-0.0273	+/- 0.025%
21 0%	-0.0013	0.0033	0.0047	-0.0033	-0.0200	-0.0167	-0.0033	-0.0167	-0.0133	

Test Cycle	1			2			3			Ref. Std.	
Test Point	Ref. Value	DUT Value	Difference	Ref. Value	DUT Value	Difference	Ref. Value	DUT Value	Difference	% Reading	
1	0%	0.0013	0.0133	0.0120	-0.0013	0.0033	0.0046	-0.0033	-0.0200	-0.0167	
2	2%	1.9987	2.0167	0.0180	2.0023	1.9800	-0.0223	2.0007	2.0233	0.0226	+/- 0.025%
3	4%	4.0000	4.0167	0.0167	3.9987	3.9867	-0.0120	4.0003	3.9767	-0.0236	+/- 0.025%
4	6%	5.9993	5.9833	-0.0160	5.9973	6.0267	0.0294	5.9983	6.0333	0.0350	+/- 0.025%
5	8%	7.9987	7.9733	-0.0254	7.9991	8.0000	0.0009	7.9977	7.9800	-0.0177	+/- 0.025%
6	10%	10.0027	10.0200	0.0173	10.0020	9.9967	-0.0053	10.0033	10.0000	-0.0033	+/- 0.025%
7	20%	20.0000	19.9767	-0.0233	19.9980	19.9700	-0.0280	20.0030	20.0133	0.0103	+/- 0.025%
8	40%	39.9967	39.9700	-0.0267	40.0020	39.9967	-0.0053	39.9983	40.0333	0.0350	+/- 0.025%
9	60%	60.0030	60.0300	0.0270	59.9990	59.9733	-0.0257	60.0013	60.0167	0.0154	+/- 0.025%
10	80%	79.9970	79.9867	-0.0103	80.0027	80.0033	0.0006	80.0017	79.9700	-0.0317	+/- 0.025%
11	100%	100.0030	99.9767	-0.0263	100.0013	100.0133	0.0120	99.9997	100.0300	0.0303	+/- 0.025%
12	80%	80.0033	79.9967	-0.0066	80.0023	79.9867	-0.0156	80.0007	80.0200	0.0193	+/- 0.025%
13	60%	60.0027	59.9700	-0.0327	59.9983	59.9933	-0.0050	59.9990	59.9900	-0.0090	+/- 0.025%
14	40%	40.0013	40.0067	0.0054	39.9973	39.9933	-0.0040	40.0013	40.0133	0.0120	+/- 0.025%
15	20%	20.0000	20.0233	0.0233	19.9993	19.9700	-0.0293	19.9990	19.9700	-0.0290	+/- 0.025%
16	10%	9.9987	9.9700	-0.0287	10.0033	10.0033	0.0000	9.9987	9.9767	-0.0220	+/- 0.025%
17	8%	7.9990	8.0000	0.0010	8.0030	8.0000	-0.0030	8.0003	7.9800	-0.0203	+/- 0.025%
18	6%	5.9987	5.9700	-0.0287	6.0027	5.9800	-0.0227	6.0007	5.9700	-0.0307	+/- 0.025%
19	4%	3.9990	4.0067	0.0077	3.9993	4.0300	0.0307	3.9970	3.9867	-0.0103	+/- 0.025%
20	2%	2.0020	1.9900	-0.0120	1.9993	2.0200	0.0207	2.0023	1.9667	-0.0356	+/- 0.025%
21	0%	0.0027	0.0300	0.0273	-0.0033	0.0133	0.0166	0.0030	-0.0167	-0.0197	

Figure B.1—Example of Transmitter Digital Test Results

B.1.1 Linearity Calculation

Linearity is calculated for each percentage of MVT point as the average of all test upscale and downscale values:

$$Linearity = \Sigma \frac{DUT - Ref}{Number\ of\ Test\ Points} \quad (B.1)$$

Linearity is calculated at each percentage of Span Test Point using the associated Test Values.

where

DUT is the Device Under Test Value;

Ref is the Reference Standard Value.

Test Cycle	1			2			3			Ref. Std.	
Test Point	Ref. Value	DUT Value	Difference	Ref. Value	DUT Value	Difference	Ref. Value	DUT Value	Difference	% Reading	
	UOM	UOM	UOM	UOM	UOM	UOM	UOM	UOM	UOM	Accuracy	
1	0%	0.0013	0.0133	0.0120	-0.0013	0.0033	0.0046	-0.0033	-0.0200	-0.0167	
2	2%	1.9987	2.0167	0.0180	2.0023	1.9800	-0.0223	2.0007	2.0233	0.0226	+/- 0.025%
3	4%	4.0000	4.0167	0.0167	3.9987	3.9867	-0.0120	4.0003	3.9767	-0.0236	+/- 0.025%
4	6%	5.9993	5.9833	-0.0160	5.9973	6.0267	0.0294	5.9983	6.0333	0.0350	+/- 0.025%
5	8%	7.9987	7.9733	-0.0254	7.9991	8.0000	0.0009	7.9977	7.9800	-0.0177	+/- 0.025%
6	10%	10.0027	10.0200	0.0173	10.0020	9.9967	-0.0053	10.0033	10.0000	-0.0033	+/- 0.025%
7	20%	20.0000	19.9767	-0.0233	19.9980	19.9700	-0.0280	20.0030	20.0133	0.0103	+/- 0.025%
8	40%	39.9967	39.9700	-0.0267	40.0020	39.9967	-0.0053	39.9983	40.0333	0.0350	+/- 0.025%
9	60%	60.0030	60.0300	0.0270	59.9990	59.9733	-0.0257	60.0013	60.0167	0.0154	+/- 0.025%
10	80%	79.9970	79.9867	-0.0103	80.0027	80.0033	0.0006	80.0017	79.9700	-0.0317	+/- 0.025%
11	100%	100.0030	99.9767	-0.0263	100.0013	100.0133	0.0120	99.9997	100.0300	0.0303	+/- 0.025%
12	80%	80.0033	79.9967	-0.0066	80.0033	10.0033	0.0000	9.9987	9.9767	-0.0220	+/- 0.025%
13	60%	60.0027	59.9700	-0.0327	59.9990	60.0033	0.0043	60.0013	60.0167	0.0154	+/- 0.025%
14	40%	40.0013	40.0067	0.0054	39.9993	40.0033	0.0040	40.0013	40.0167	0.0154	+/- 0.025%
15	20%	20.0000	20.0233	0.0233	19.9980	20.0033	0.0053	20.0030	20.0133	0.0103	+/- 0.025%
16	10%	9.9987	9.9700	-0.0287	10.0033	10.0033	0.0000	9.9987	9.9767	-0.0220	+/- 0.025%
17	8%	7.9990	8.0000	0.0010	8.0030	8.0030	0.0000	7.9987	7.9767	-0.0220	+/- 0.025%
18	6%	5.9987	5.9700	-0.0287	6.0027	6.0027	0.0000	5.9987	5.9767	-0.0220	+/- 0.025%
19	4%	3.9990	4.0067	0.0077	3.9993	4.0033	0.0040	3.9987	3.9767	-0.0220	+/- 0.025%
20	2%	2.0020	1.9900	-0.0120	1.9993	2.0033	0.0040	2.0017	2.0017	0.0000	+/- 0.025%
21	0%	0.0027	0.0300	0.0273	-0.0033	0.0133	0.0166	0.0030	-0.0167	-0.0197	

Linearity (Test Cycle 1)
 $= -0.0120 + 0.0273 = 0.0197$
 2

Linearity (All Test Cycles)
 $= 0.0164 + 0.0106 - 0.0182 = 0.0040$
 3

Linearity/Repeatability/Hysteresis Calculations for Each Test Cycle										
Test Cycle	1			2			3			Ref. Std.
Test Point	Ref. Value	Hysteresis	Linearity	Ref. Value	Hysteresis	Linearity	Ref. Value	Hysteresis	Linearity	% Reading
0%	0.0		0.0197	0.0		0.0106	0.0		-0.0182	+/- 0.025%
2%	2.0	-0.0300	0.0030	2.0	0.0430	0.0065	2.0	-0.0582	0.0065	+/- 0.025%
4%	4.0	-0.0090	0.0122	4.0	0.0427	0.0094	4.0	0.0133	-0.0170	+/- 0.025%
6%	6.0	-0.0127	-0.0224	6.0	-0.0521	0.0034	6.0	-0.0657	0.0021	+/- 0.025%
8%	8.0	0.0264	-0.0122	8.0	-0.0039	-0.0011	8.0	-0.0026	-0.0190	+/- 0.025%
10%	10.0	-0.0460	-0.0057	10.0	0.0053	-0.0027	10.0	-0.0187	-0.0126	+/- 0.025%
20%	20.0	0.0466	0.0000	20.0	-0.0013	-0.0287	20.0	-0.0393	-0.0093	+/- 0.025%
40%	40.0	0.0321	-0.0105	40.0	0.0013	-0.0047	40.0	-0.0230	0.0235	+/- 0.025%
60%	60.0	-0.0597	-0.0028	60.0	0.0207	-0.0154	60.0	-0.0244	0.0032	+/- 0.025%
80%	80.0	0.0037	0.0084	80.0	-0.0162	-0.0075	80.0	0.0510	-0.0062	+/- 0.025%
100%	100.0		-0.0263	100.0		0.0120	100.0		0.0303	+/- 0.025%

Summary Calculations														
Test Point	Ref. Value	UOM	Linearity	% MTV	% Reading	Repeatability	UOM	% MTV	% Reading	Hysteresis	UOM	% MTV	% Reading	Ref. Std.
0%	0.0		0.0040	0.004%		0.0235	0.024%							
2%	2.0		0.0015	0.001%	0.072%	0.0282	0.028%	1.408%		0.0430	0.043%	2.150%		+/- 0.025%
4%	4.0		0.0015	0.002%	0.038%	0.0205	0.021%	0.513%		0.0427	0.043%	1.068%		+/- 0.025%
6%	6.0		-0.0056	-0.006%	-0.094%	0.0255	0.025%	0.425%		-0.0127	-0.013%	-0.212%		+/- 0.025%
8%	8.0		-0.0107	-0.011%	-0.134%	0.0132	0.013%	0.164%		0.0264	0.026%	0.330%		+/- 0.025%
10%	10.0		-0.0070	-0.007%	-0.070%	0.0143	0.014%	0.143%		0.0053	0.005%	0.053%		+/- 0.025%
20%	20.0		-0.0127	-0.013%	-0.063%	0.0263	0.026%	0.132%		0.0466	0.047%	0.233%		+/- 0.025%
40%	40.0		0.0027	0.003%	0.007%	0.0308	0.031%	0.077%		0.0321	0.032%	0.080%		+/- 0.025%
60%	60.0		-0.0050	-0.005%	-0.008%	0.0264	0.026%	0.044%		0.0207	0.021%	0.034%		+/- 0.025%
80%	80.0		-0.0074	-0.007%	-0.009%	0.0175	0.017%	0.022%		0.0510	0.051%	0.064%		+/- 0.025%
100%	100.0		0.0053	0.005%	0.005%	0.0283	0.028%	0.028%						+/- 0.025%

For

Test Cycle	1			2			3			Ref. Std.
Test Point	Ref. Value	DUT Value	Difference	Ref. Value	DUT Value	Difference	Ref. Value	DUT Value	Difference	% Reading
1	0%	0.0013	0.0133	-0.0013	0.0033	0.0046	-0.0033	-0.0200	-0.0167	
2	2%	1.9987	2.0167	2.0023	1.9800	-0.0223	2.0007	2.0233	0.0226	+/- 0.025%
3	4%	4.0000	4.0167	3.9987	3.9867	-0.0120	4.0003	3.9767	-0.0236	+/- 0.025%
4	6%	5.9993	5.9833	5.9973	6.0267	0.0294	5.9983	6.0333	0.0350	+/- 0.025%
5	8%	7.9987	7.9733	7.9991	8.0000	0.0009	7.9977	7.9800	-0.0177	+/- 0.025%
6	10%	10.0027	10.0200	10.0020	9.9967	-0.0053	10.0033	10.0000	-0.0033	+/- 0.025%
7	20%	20.0000	19.9767	19.9980	19.9700	-0.0280	20.0030	20.0133	0.0103	+/- 0.025%
8	40%	39.9967	39.9700	40.0020	39.9967	-0.0053	39.9983	40.0333	0.0350	+/- 0.025%
9	60%	60.0030	60.0300	60.0270	59.9990	-0.0257	60.0013	60.0167	0.0154	+/- 0.025%
10	80%	79.9970	79.9867	80.0027	80.0033	0.0006	80.0017	79.9700	-0.0317	+/- 0.025%
11	100%	100.0030	99.9767	100.0013	100.0133	0.0120	99.9997	100.0300	0.0303	+/- 0.025%
12	80%	80.0033	79.9967	80.0033	80.0033	0.0000	80.0033	80.0200	0.0167	+/- 0.025%
13	60%	60.0027	59.9700	59.9990	59.9990	-0.0090	59.9990	59.9990	-0.0090	+/- 0.025%
14	40%	40.0013	40.0067	39.9993	39.9993	0.0000	40.0133	40.0133	0.0120	+/- 0.025%
15	20%	20.0000	20.0233	19.9993	19.9993	0.0000	19.9993	19.9700	-0.0293	+/- 0.025%
16	10%	9.9987	9.9700	10.0033	10.0033	0.0000	9.9987	9.9767	-0.0220	+/- 0.025%
17	8%	7.9990	8.0000	8.0030	8.0030	0.0000	7.9990	7.9990	0.0000	+/- 0.025%
18	6%	5.9987	5.9700	6.0027	6.0027	0.0000	5.9987	5.9987	0.0000	+/- 0.025%
19	4%	3.9990	4.0067	3.9993	3.9993	0.0000	3.9990	3.9990	0.0000	+/- 0.025%
20	2%	2.0020	1.9900	2.0020	2.0020	0.0000	2.0020	2.0020	0.0000	+/- 0.025%
21	0%	0.0027	0.0300	0.0033	0.0133	0.0100	0.0030	0.0167	0.0137	+/- 0.025%

Linearity/Repeatability/Hysteresis Calculations for Each Test Cycle										
Test Cycle	1			2			3			Ref. Std.
Test Point	Ref. Value	Hysteresis	Linearity	Ref. Value	Hysteresis	Linearity	Ref. Value	Hysteresis	Linearity	% Reading
0%	0.0		0.0197	0.0		0.0106	0.0		-0.0182	+/- 0.025%
2%	2.0	-0.0300	0.0030	2.0	0.0430	0.0008	2.0	-0.0582	0.0065	+/- 0.025%
4%	4.0	-0.0090	0.0122	4.0	0.0427	0.0094	4.0	0.0133	-0.0170	+/- 0.025%
6%	6.0	-0.0127	-0.0224	6.0	-0.0521	0.0034	6.0	-0.0657	0.0021	+/- 0.025%
8%	8.0	0.0264	-0.0122	8.0	-0.0039	-0.0011	8.0	-0.0026	-0.0190	+/- 0.025%
10%	10.0	-0.0460	-0.0057	10.0	0.0053	-0.0027	10.0	-0.0187	-0.0126	+/- 0.025%
20%	20.0	0.0466	0.0000	20.0	-0.0013	-0.0287	20.0	-0.0393	-0.0093	+/- 0.025%
40%	40.0	0.0321	-0.0106	40.0	0.0013	-0.0047	40.0	-0.0230	0.0235	+/- 0.025%
60%	60.0	-0.0597	-0.0028	60.0	0.0207	-0.0154	60.0	-0.0244	0.0032	+/- 0.025%
80%	80.0	0.0037	-0.0084	80.0	-0.0162	-0.0075	80.0	0.0510	-0.0062	+/- 0.025%
100%	100.0		-0.0263	100.0		0.0120	100.0		0.0303	+/- 0.025%

Summary Calculations													
Test Point	Linearity			Repeatability			Hysteresis			API 22.4 Baseline Accuracy			Ref. Std.
Ref. Value	UOM	% MTV	% Reading	UOM	% MTV	% Reading	UOM	% MTV	% Reading	UOM	% MTV	% Reading	% Reading
0%	0.0	0.0040	0.004%	0.0308	0.031%					+/- 0.0311	+/- 0.031%		
2%	2.0	-0.0014	-0.001%	0.0308	0.031%	1.542%	0.0582	0.058%	2.910%	+/- 0.0659	+/- 0.066%	+/- 3.294%	+/- 0.025%
4%	4.0	0.0015	0.002%	0.0308	0.031%	0.771%	0.0427	0.043%	1.068%	+/- 0.0527	+/- 0.053%	+/- 1.318%	+/- 0.025%
6%	6.0	-0.0056	-0.006%	0.0308	0.031%	0.514%	0.0657	0.066%	1.095%	+/- 0.0728	+/- 0.073%	+/- 1.213%	+/- 0.025%
8%	8.0	-0.0107	-0.011%	0.0308	0.031%	0.386%	0.0264	0.026%	0.330%	+/- 0.0420	+/- 0.042%	+/- 0.525%	+/- 0.025%
10%	10.0	-0.0070	-0.007%	0.0308	0.031%	0.308%	0.0460	0.046%	0.460%	+/- 0.0558	+/- 0.056%	+/- 0.558%	+/- 0.025%
20%	20.0	-0.0127	-0.013%	0.0308	0.031%	0.154%	0.0466	0.047%	0.233%	+/- 0.0573	+/- 0.057%	+/- 0.287%	+/- 0.025%
40%	40.0	0.0027	0.003%	0.0308	0.031%	0.077%	0.0321	0.032%	0.080%	+/- 0.0446	+/- 0.045%	+/- 0.112%	+/- 0.025%
60%	60.0	-0.0050	-0.005%	0.0308	0.031%	0.051%	0.0597	0.060%	0.099%	+/- 0.0674	+/- 0.067%	+/- 0.112%	+/- 0.025%
80%	80.0	-0.0074	-0.007%	0.0308	0.031%	0.039%	0.0510	0.051%	0.064%	+/- 0.0601	+/- 0.060%	+/- 0.075%	+/- 0.025%
100%	100.0	0.0053	0.005%	0.0308	0.031%	0.031%				+/- 0.0313	+/- 0.031%	+/- 0.031%	+/- 0.025%

Figure B.2—Example of Transmitter Digital Test Results Linearity Calculations

B.1.2 Repeatability Calculation

Repeatability is calculated for each percentage of span point as the maximum minus the minimum of all repeat test upscale and downscale values:

$$\text{Repeatability} = \left(\max \left([DUT - Ref]_{\text{upscale or downscale}} - \min [DUT - Ref]_{\text{upscale or downscale}} \right) \right) / 2 \quad (\text{B.2})$$

Repeatability is calculated at each percentage of Span Point using the associated Upscale and Downscale Test

Values.

where

DUT is the Device Under Test Value;

Ref is the Reference Standard Value.

Test Cycle	1			2			3			Ref. Std
Test Point	Ref. Value	DUT Value	Difference	Ref. Value	DUT Value	Difference	Ref. Value	DUT Value	Difference	% Reading
1 0%	-0.0010	-0.0200	-0.0190	-0.0023	0.0033	0.0057	0.0013	0.0300	0.0287	+/- 0.025%
2 2%	1.9980	1.9800	-0.0180	1.9977	2.0133	0.0157	2.0033	2.0100	0.0067	+/- 0.025%
3 4%	3.9977	3.9700	-0.0277	4.0000	4.0233	0.0233	4.0013	4.0033	0.0020	+/- 0.025%
4 6%	5.9967	6.0200	0.0233	5.9987	6.0100	0.0113	5.9967	6.0100	0.0133	+/- 0.025%
5 8%	7.9993	7.9687	-0.0307	7.9973	7.9667	-0.0307	7.9977	8.0067	0.0090	+/- 0.025%
6 10%	9.9967	10.0200	0.0233	10.0007	10.0133	0.0127	9.9990	10.0100	0.0110	+/- 0.025%
7 20%	20.0023	19.9667	-0.0357	20.0027	20.0300	0.0273	20.0010	19.9800	-0.0210	+/- 0.025%
8 40%										+/- 0.025%
9 60%										+/- 0.025%
10 80%										+/- 0.025%
11 100%										+/- 0.025%
12 0%										+/- 0.025%
13 20%										+/- 0.025%
14 40%										+/- 0.025%
15 20%	20.0000	20.0067	0.0067	20.0003	20.0133	0.0130	19.9980	19.9700	-0.0280	+/- 0.025%
16 10%	9.9997	10.0000	0.0003	10.0020	10.0200	0.0180	10.0033	9.9933	-0.0100	+/- 0.025%
17 8%	8.0023	7.9900	-0.0123	8.0017	7.9767	-0.0250	8.0020	8.0100	0.0080	+/- 0.025%
18 6%	5.9997	6.0033	0.0037	5.9993	6.0000	0.0007	6.0007	5.9933	-0.0073	+/- 0.025%
19 4%	3.9997	3.9667	-0.0330	3.9980	4.0167	0.0187	4.0007	3.9900	-0.0107	+/- 0.025%
20 2%	2.0007	1.9700	-0.0307	2.0027	2.0267	0.0240	1.9973	1.9700	-0.0273	+/- 0.025%
21 0%	-0.0013	0.0033	0.0047	-0.0033	-0.0200	-0.0167	-0.0033	-0.0167	-0.0133	+/- 0.025%

Repeatability/Hysteresis Calculation				
Test Point	Upscale Repeatability	Downscale Repeatability	Test Point	Hysteresis
0%	+/- 0.0107	+/- 0.0107	2%	0.0083
2%	+/- 0.0168	+/- 0.0273	4%	-0.0047
4%	+/- 0.0255	+/- 0.0258	6%	-0.0107
6%	+/- 0.0060	+/- 0.0055	8%	0.0203
8%	+/- 0.0208	+/- 0.0165	10%	0.0053
10%	+/- 0.0062	+/- 0.0140	20%	0.0423
20%	+/- 0.0315	+/- 0.0205	40%	0.0157
40%	+/- 0.0080	+/- 0.0145	60%	-0.0117
60%	+/- 0.0110	+/- 0.0267	80%	0.0037
80%	+/- 0.0075	+/- 0.0245	100%	0.0423
100%	+/- 0.0258		Max Hysteresis	0.0423
Max Repeatability	+/- 0.0315		Test Hysteresis	#N/A

Test Cycle	1			2			3			Ref. Std.
Test Point	Ref. Value	DUT Value	Difference	Ref. Value	DUT Value	Difference	Ref. Value	DUT Value	Difference	% Reading
1 0%	0.0013	0.0133	0.0120	-0.0013	0.0033	0.0046	-0.0033	-0.0200	-0.0167	+/- 0.025%
2 2%	1.9987	2.0167	0.0180	2.0023	1.9800	-0.0223	2.0007	2.0233	0.0226	+/- 0.025%
3 4%	4.0000	4.0167	0.0167	3.9987	3.9867	-0.0120	4.0003	3.9767	-0.0236	+/- 0.025%
4 6%	5.9993	5.9833	-0.0160	5.9973	6.0267	0.0294	5.9983	6.0333	0.0350	+/- 0.025%
5 8%	7.9987	7.9733	-0.0254	7.9991	8.0000	0.0009	7.9977	7.9800	-0.0177	+/- 0.025%
6 10%	10.0027	10.0200	0.0173	10.0020	9.9967	-0.0053	10.0033	10.0000	-0.0033	+/- 0.025%
7 20%	20.0000	19.9767	-0.0233	19.9980	19.9700	-0.0280	20.0030	20.0133	0.0103	+/- 0.025%
8 40%										+/- 0.025%
9 60%										+/- 0.025%
10 80%										+/- 0.025%
11 100%										+/- 0.025%
12 0%										+/- 0.025%
13 20%										+/- 0.025%
14 40%										+/- 0.025%
15 20%	20.0000	20.0233	0.0233	19.9993	19.9700	-0.0293	19.9990	19.9700	-0.0290	+/- 0.025%
16 10%	9.9987	9.9700	-0.0287	10.0033	10.0033	0.0000	9.9987	9.9767	-0.0220	+/- 0.025%
17 8%	7.9990	8.0000	0.0010	8.0030	8.0000	-0.0030	8.0003	7.9800	-0.0203	+/- 0.025%
18 6%	5.9987	5.9700	-0.0287	6.0027	5.9800	-0.0227	6.0007	5.9700	-0.0307	+/- 0.025%
19 4%	3.9990	4.0067	0.0077	3.9993	4.0300	0.0307	3.9970	3.9867	-0.0103	+/- 0.025%
20 2%	2.0020	1.9900	-0.0120	1.9993	2.0200	0.0207	2.0023	1.9667	-0.0356	+/- 0.025%
21 0%	0.0027	0.0300	0.0273	-0.0033	0.0133	0.0166	0.0030	-0.0167	-0.0197	+/- 0.025%

Repeatability/Hysteresis Calculation				
Test Point	Upscale Repeatability	Downscale Repeatability	Test Point	Hysteresis
0%		0.0235		
2%	0.0224	0.0282	2%	0.0582
4%	0.0202	0.0205	4%	0.0427
6%	0.0255	0.0040	6%	0.0657
8%	0.0132	0.0106	8%	0.0264
10%	0.0113	0.0143	10%	0.0460
20%	0.0192	0.0263	20%	0.0466
40%	0.0308	0.0080	40%	0.0321
60%	0.0264	0.0138	60%	0.0597
80%	0.0161	0.0175	80%	0.0510
100%	0.0283			

Figure B.3—Example of Transmitter Digital Test Results Repeatability Calculations

B.1.3 Hysteresis Calculation

Hysteresis is calculated for each percentage of span point as the maximum downscale minus upscale value of each repeat test:

$$Hysteresis = \max(|[DUT - Ref]_{downscale} - [DUT - Ref]_{upscale}|)_{each\ report\ test}$$

$$Hysteresis = \max(|[DUT - Ref]_{downscale} - [DUT - Ref]_{upscale}|)_{each\ report\ test}$$

(B.2

3)

Hysteresis is calculated at each percentage of Span Point.

where

DUT is the Device Under Test Value;

Ref is the Reference Standard Value.




Figure B.4—Example of Transmitter Digital Test Results Hysteresis Calculations

B.1.4 API 22.4 Baseline Accuracy and Summary Calculation

API 22.4 Baseline Accuracy is calculated for each percentage of span point as root mean square of Linearity and the maximum Repeatability and Hysteresis values as shown in Figure B.6. The Reference Standard accuracy for each test point is reported.

$$API\ 22.4\ Baseline\ Accuracy = \sqrt{(Linearity)^2 + (\max(Repeatability))^2 + (\max(Hysteresis))^2}$$

$$Reference\ Accuracy = \sqrt{((Linearity)^2 + (\max(Repeatability))^2 + (\max(Hysteresis))^2)} \quad (B.4)$$

Test Cycle	1	2	3	Ref. Std.
Test Point	Ref. Value	DUT Value	Difference	% Reading
1 0%	-0.0010	-0.0200	-0.0190	-0.0023
2 2%	1.9980	1.9800	-0.0180	1.9977
3 4%	3.9977	3.9700	-0.0277	4.0000
4 6%	5.9967	6.0200	0.0233	5.9987
5 8%	7.9993	7.9667	-0.0327	7.9973
6 10%	9.9967	10.0200	0.0233	10.0007
7 20%	20.0023	19.9667	-0.0357	20.0027
8 40%	40.0013	39.9733	-0.0280	40.0010
9 60%	59.9970	60.0333	0.0363	60.0023
10 80%	79.9980	80.0067	0.0087	79.9967
11 100%	100.0007	100.0100	0.0093	99.9973
12 80%	80.0010	80.0133	0.0123	80.0033
13 60%	60.0007	59.9667	-0.0340	59.9970
14 40%	39.9990	39.9700	-0.0290	40.0027
15 20%	20.0000	20.0067	0.0067	20.0003
16 10%	9.9997	10.0000	0.0003	10.0020
17 8%	8.0023	7.9900	-0.0123	8.0017
18 6%	5.9997	6.0033	0.0037	5.9993
19 4%	3.9997	3.9667	-0.0330	3.9980
20 2%	2.0007	1.9700	-0.0307	2.0027
21 0%	-0.0013	0.0033	0.0047	-0.0033

Test Cycle	1	2	3	Ref. Std.
Test Point	Ref. Value	DUT Value	Difference	% Reading
1 0%	0.0013	0.0133	0.0120	-0.0013
2 2%	1.9987	2.0167	0.0180	2.0023
3 4%	4.0000	4.0167	0.0167	3.9987
4 6%	5.9993	5.9833	-0.0160	5.9973
5 8%	7.9987	7.9733	-0.0254	7.9991
6 10%	10.0027	10.0200	0.0173	10.0020
7 20%	20.0000	19.9767	-0.0233	19.9980
8 40%	39.9967	39.9700	-0.0267	40.0020
9 60%	60.0030	60.0300	0.0270	59.9990
10 80%	79.9970	79.9867	-0.0103	80.0027
11 100%	100.0030	99.9767	-0.0263	100.0013
12 80%	80.0033	79.9967	-0.0066	80.0023
13 60%	60.0027	59.9700	-0.0327	59.9983
14 40%	40.0013	40.0067	0.0054	39.9973
15 20%	20.0000	20.0233	0.0233	19.9993
16 10%	9.9987	9.9700	-0.0287	10.0033
17 8%	7.9990	8.0000	0.0010	8.0030
18 6%	5.9987	5.9700	-0.0287	6.0027
19 4%	3.9990	4.0067	0.0077	3.9993
20 2%	2.0020	1.9900	-0.0120	1.9993
21 0%	0.0027	0.0300	0.0273	-0.0033

Figure B.5—Example Test Results

Test Cycle	1	2	3	Ref. Std.
Test Point	Ref. Value	Hysteresis	Linearity	% Reading
0%	0.0	-0.0127	-0.0072	0.0077
2%	2.0	-0.0053	-0.0243	0.0198
4%	4.0	-0.0197	0.0135	0.0060
6%	6.0	0.0203	-0.0225	-0.0278
8%	8.0	-0.0230	0.0118	0.0153
10%	10.0	0.0423	-0.0145	0.0202
20%	20.0	-0.0010	-0.0285	0.0117
40%	40.0	-0.0703	0.0012	-0.0313
60%	60.0	0.0037	0.0105	-0.0117
80%	80.0	0.0093	0.0093	-0.0500
100%	100.0			-0.0117

Linearity/Repeatability/Hysteresis Calculations for Each Test Cycle									
Test Cycle	1			2			3		
Test Point	Ref. Value	Hysteresis	Linearity	Ref. Value	Hysteresis	Linearity	Ref. Value	Hysteresis	Ref. Std.
0%	0.0		0.0197	0.0		0.0106	0.0	-0.0182	+/- 0.025%
2%	2.0	-0.0300	0.0030	2.0	0.0430	-0.0008	2.0	-0.0582	+/- 0.025%
4%	4.0	-0.0090	0.0122	4.0	0.0427	0.0094	4.0	0.0133	+/- 0.025%
6%	6.0	-0.0127	-0.0224	6.0	-0.0521	0.0034	6.0	-0.0657	+/- 0.025%
8%	8.0	0.0264	-0.0122	8.0	-0.0039	-0.0011	8.0	-0.0026	+/- 0.025%
10%	10.0	-0.0460	-0.0057	10.0	0.0053	-0.0027	10.0	-0.0187	+/- 0.025%
20%	20.0	0.0466	0.0000	20.0	-0.0013	-0.0287	20.0	-0.0393	+/- 0.025%
40%	40.0	0.0321	-0.0106	40.0	0.0013	-0.0047	40.0	-0.0230	+/- 0.025%
60%	60.0	-0.0597	-0.0028	60.0	0.0207	-0.0154	60.0	-0.0244	+/- 0.025%
80%	80.0	0.0037	-0.0084	80.0	-0.0162	-0.0075	80.0	0.0510	+/- 0.025%
100%	100.0		-0.0263	100.0		0.0120	100.0	0.0303	+/- 0.025%

Repeatability/Hysteresis Calculation				
Test Point	Upscale Repeatability	Downscale Repeatability	Test Point	Hysteresis
0%	+/- 0.0168	+/- 0.0107	2%	0.0083
2%	+/- 0.0255	+/- 0.0273	4%	-0.0047
4%	+/- 0.0060	+/- 0.0055	6%	-0.0107
6%	+/- 0.0208	+/- 0.0185	8%	0.0203
8%	+/- 0.0062	+/- 0.0140	10%	0.0053
10%	+/- 0.0315	+/- 0.0205	20%	0.0423
20%	+/- 0.0085	+/- 0.0148	40%	0.0157
40%	+/- 0.0110	+/- 0.0267	60%	-0.0117
60%	+/- 0.0075	+/- 0.0245	80%	0.0037
80%	+/- 0.0258	+/-	100%	0.0423
Max Repeatability				0.0315

Repeatability/Hysteresis Calculation			
Test Point	Upscale	Downscale	Hysteresis
0%	0.0235		
2%	0.0224	0.0282	0.0582
4%	0.0202	0.0205	0.0427
6%	0.0255	0.0040	0.0657
8%	0.0132	0.0106	0.0264
10%	0.0113	0.0143	0.0460
20%	0.0192	0.0263	0.0466
40%	0.0308	0.0080	0.0321
60%	0.0264	0.0138	0.0597
80%	0.0161	0.0175	0.0510
100%	0.0283		

Summary Calculations													
Test Point	Linearity			Repeatability			Hysteresis			Reference Accuracy			Ref Std
Ref Value	% URL	% Reading		% URL	% Reading		% URL	% Reading		% URL	% Reading	% Reading	
0%	0.0	-0.0017	0.017%	+/- 0.0315	+/- 0.315%	+/- 0.0423	+/- 0.423%		+/- 0.0528	+/- 0.528%		+/- 0.025%	
2%	2.0	-0.0049	-0.049%	+/- 0.0315	+/- 0.315%	+/- 0.0423	+/- 0.423%	+/- 2.117%	+/- 0.0530	+/- 0.530%	+/- 1.324%	+/- 0.025%	
4%	4.0	-0.0046	-0.046%	+/- 0.0315	+/- 0.315%	+/- 0.0423	+/- 0.423%	+/- 1.058%	+/- 0.0530	+/- 0.530%	+/- 0.888%	+/- 0.025%	
6%	6.0	0.0075	0.075%	+/- 0.0315	+/- 0.315%	+/- 0.0423	+/- 0.423%	+/- 0.708%	+/- 0.0533	+/- 0.533%	+/- 0.682%	+/- 0.025%	
8%	8.0	-0.0139	-0.139%	+/- 0.0315	+/- 0.315%	+/- 0.0423	+/- 0.423%	+/- 0.529%	+/- 0.0546	+/- 0.546%	+/- 0.536%	+/- 0.025%	
10%	10.0	0.0092	0.092%	+/- 0.0315	+/- 0.315%	+/- 0.0423	+/- 0.423%	+/- 0.423%	+/- 0.0536	+/- 0.536%	+/- 0.266%	+/- 0.025%	
20%	20.0	-0.0083	-0.083%	+/- 0.0315	+/- 0.315%	+/- 0.0423	+/- 0.423%	+/- 0.212%	+/- 0.0531	+/- 0.531%	+/- 0.139%	+/- 0.025%	
40%	40.0	-0.0171	-0.171%	+/- 0.0315	+/- 0.315%	+/- 0.0423	+/- 0.423%	+/- 0.106%	+/- 0.0555	+/- 0.555%	+/- 0.089%	+/- 0.025%	
60%	60.0	0.0083	0.083%	+/- 0.0315	+/- 0.315%	+/- 0.0423	+/- 0.423%	+/- 0.071%	+/- 0.0534	+/- 0.534%	+/- 0.066%	+/- 0.025%	
80%	80.0	-0.0008	-0.008%	+/- 0.0315	+/- 0.315%	+/- 0.0423	+/- 0.423%	+/- 0.053%	+/- 0.0528	+/- 0.528%	+/- 0.528%	+/- 0.025%	
100%	10.0	0.0028	0.028%	+/- 0.0315	+/- 0.315%	+/- 0.0423	+/- 0.423%	+/- 0.0423%	+/- 0.0528	+/- 0.528%	+/- 0.528%	+/- 0.025%	
Maximum - Minimum Linearity		0.372%											

Summary Calculations																
Test Point	Linearity						Repeatability			Hysteresis			API 22.4 Baseline Accuracy			Ref. Std.
Ref. Value	UOM	% MTV	% Reading	UOM	% MTV	% Reading	UOM	% MTV	% Reading	UOM	% MTV	% Reading	UOM	% MTV	% Reading	% Reading
0%	0.0	0.0040	0.004%		0.0308	0.031%				+/- 0.0311	+/- 0.031%					
2%	2.0	-0.0014	-0.001%	-0.072%	0.0308	0.031%	1.542%	0.0582	0.058%	2.910%	+/- 0.0659	+/- 0.066%	+/- 3.294%	+/- 0.025%		
4%	4.0	0.0015	0.002%	0.038%	0.0308	0.031%	0.771%	0.0427	0.043%	1.068%	+/- 0.0527	+/- 0.053%	+/- 1.318%	+/- 0.025%		
6%	6.0	-0.0056	-0.006%	-0.094%	0.0308	0.031%	0.514%	0.0657	0.066%	1.095%	+/- 0.0728	+/- 0.073%	+/- 1.213%	+/- 0.025%		
8%	8.0	-0.0107	-0.011%	-0.134%	0.0308	0.031%	0.386%	0.0264	0.026%	0.330%	+/- 0.0420	+/- 0.042%	+/- 0.525%	+/- 0.025%		
10%	10.0	-0.0070	-0.007%	-0.070%	0.0308	0.031%	0.308%	0.0460	0.046%	0.460%	+/- 0.0558	+/- 0.056%	+/- 0.558%	+/- 0.025%		
20%	20.0	-0.0127	-0.013%	-0.063%	0.0308	0.031%	0.154%	0.0466	0.047%	0.233%	+/- 0.0573	+/- 0.057%	+/- 0.287%	+/- 0.025%		
40%	40.0	0.0027	0.003%	0.007%	0.0308	0.031%	0.077%	0.0321	0.032%	0.080%	+/- 0.0446	+/- 0.045%	+/- 0.112%	+/- 0.025%		
60%	60.0	-0.0050	-0.005%	-0.008%	0.0308	0.031%	0.051%	0.0597	0.060%	0.099%	+/- 0.0674	+/- 0.067%	+/- 0.112%	+/- 0.025%		
80%	80.0	-0.0074	-0.007%	-0.009%	0.0308	0.031%	0.039%	0.0510	0.051%	0.064%	+/- 0.0601	+/- 0.060%	+/- 0.075%	+/- 0.025%		
100%	100.0	0.0053	0.005%	0.005%	0.0308	0.031%	0.031%				+/- 0.0313	+/- 0.031%	+/- 0.031%	+/- 0.025%		

Figure B.6—Example Calculations Based on Test Results in Figure B.5